



Notified Body No. 0370

CERTIFICATE



No.

0370-CPR-2347

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation *305/2011/EU* of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 11: MANUAL CALL POINTS
MODEL: **PCD-100**

Place on the market under the name of:

DETNOV SECURITY, S.L.

CARRER DE L'ALGUER, 8 - POL. IND. LES SALINES
08830 SANT BOI DE LLOBREGAT (BARCELONA - SPAIN)

And produced in the manufacturing plant:

20/32300668

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:


EN 54-11:2001, EN 54-11:2001/A1:2005

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 22nd January 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed on 29th May 2020.

The monitoring assessment will be done before 31st May 2021

Bellaterra, 29th May 2020


Applus⁺
LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate into our website at: <https://apps.applus.com/microsites/microsites/FECIP/login>

0370-CPR-2347

Annex according to **EN 54-11:2001, EN 54-11:2001/A1:2005**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Marking and data	4.2	PASS
Normal condition	4.3.1	PASS
Alarm condition	4.3.2	PASS
Indicators for alarm condition	4.4	PASS
Reset facility	4.5	PASS
Test facility	4.6	PASS
Shape, dimensions and colours	4.7.2	PASS
Symbols and lettering	4.7.3	PASS
Protection against accidental operation	4.7.4	PASS
Environment category	4.7.5	PASS
Additional requirements for software controlled manual call points	4.8	NA
Operational performance test	5.2	PASS
Function test	5.3	PASS
Test facility test (operational)	5.4	PASS
Reliability test (endurance)	5.5	PASS
Variation of supply parameters	5.6	PASS
Dry heat (operational)	5.7	PASS
Dry heat (endurance)	5.8	NA
Cold (operational)	5.9	PASS
Damp heat, cyclic (operational)	5.10	PASS
Damp heat, cyclic (endurance)	5.11	NA
Damp heat, steady state (endurance)	5.12	PASS
SO2 corrosion (endurance)	5.13	PASS
Shock (operational)	5.14	PASS
Impact (operational)	5.15	PASS
Vibration, sinusoidal (operational)	5.16	PASS
Vibration, sinusoidal (endurance)	5.17	PASS
Electromagnetic compatibility (EMC) (operational)	5.18	PASS
Enclosure protection	5.19	NA

PASS; NPD = No Performance Determined, NA = Not Apply