

Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Detnov Security, S.L.

C/ De La Ciència, 30-32
08840 Viladecans (Barcelona) Spain

Produced in the manufacturing plant

C/ De La Ciència, 30-32
08840 Viladecans (Barcelona) Spain

PRODUCT

Fire detection and fire alarm systems

- Heat detectors – point heat detectors
- Smoke detectors. Point smoke detectors that operate using scattered light, transmitted light or ionization
- Short-circuit isolators

Models: DOTD-330A-I / DOTD-330A-I-B

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards:

EN 54-5:2017+A1:2018; EN 54-7:2018; EN 54-17:2005, EN 54-17:2005/AC:2007

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility
Page 1 of 4

No. 0370-CPR-7620

Date issued: 30/01/2026

First issue date: 03/10/2025

Modification date: 30/01/2026

Follow-up date: before 30/09/2026

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the AVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment

Applus⁺ certification

LGAI Technological Center S.A. (APPLUS)

Notified Body No. 0370

Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 54-5:2017+A1:2018

Fire detection and fire alarm systems - Part 5: Heat detectors - Point heat detectors

| Essential characteristics | Clauses in this European standard | Mandated level(s) or class(es) |
|---|-----------------------------------|--------------------------------|
| Heat Response Categories | 4.1.1 | A2R |
| Position of heat sensitive element | 4.2.1 | Pass |
| Individual alarm indication | 4.2.2 | Pass |
| Connection of ancillary devices | 4.2.3 | Pass |
| Monitoring of detachable detectors | 4.2.4 | Pass |
| Manufacturer's adjustments | 4.2.5 | Pass |
| On-site adjustment of response behavior | 4.2.6 | Pass |
| Software controlled detector (when provided) | 4.2.7 | Pass |
| Directional dependence | 4.3.1 | Pass |
| Static response temperature | 4.3.2 | Pass |
| Response times from typical application temperature | 4.3.3 | Pass |
| Response times from 25 °C | 4.3.4 | Pass |
| Response times from high ambient temperature | 4.3.5 | Pass |
| Reproducibility | 4.3.6 | Pass |
| Additional test for heat suffix S detectors | 4.4.1 | Na |
| Additional test for heat suffix R detectors | 4.4.2 | Pass |
| Variation in supply parameters | 4.5.1 | Pass |
| Cold (operational) | 4.6.1.1 | Pass |
| Dry heat (endurance) | 4.6.1.2 | Na |
| Damp heat, cyclic (operational) | 4.6.2.1 | Pass |
| Damp heat, steady state (endurance) | 4.6.2.2 | Pass |
| Sulfur dioxide (SO ₂) corrosion (endurance) | 4.6.3 | Pass |
| Shock (operational) | 4.6.4.1 | Pass |
| Impact (operational) | 4.6.4.2 | Pass |
| Vibration, sinusoidal (operational) | 4.6.4.3 | Pass |
| Vibration, sinusoidal (endurance) | 4.6.4.4 | Pass |
| EMC, immunity (operational) | 4.6.5 | Pass |

PASS; NPD = No Performance Determined, NA = Not Apply

Annex according to EN 54-7:2018

Fire detection and fire alarm systems. Part 7: Smoke detectors - Point smoke detectors that operate using scattered light, transmitted light or ionization

| Essential characteristics | Clauses in this European standard | Mandated level(s) or class(es) |
|---|-----------------------------------|--------------------------------|
| Individual alarm indication | 4.2.1 | Pass |
| Connection of ancillary devices | 4.2.2 | Pass |
| Monitoring of heat detachable detectors | 4.2.3 | Pass |
| Manufacturer's adjustments | 4.2.4 | Pass |
| On-site adjustment of response behavior | 4.2.5 | Pass |
| Protection against the ingress of foreign bodies | 4.2.6 | Pass |
| Response to slowly developing fires | 4.2.7 | Pass |
| Software controlled detector (when provided) | 4.2.8 | Pass |
| Repeatability | 4.3.1 | Pass |
| Directional dependence | 4.3.2 | Pass |
| Reproducibility | 4.3.3 | Pass |
| Air movement | 4.4-1 | Pass |
| Dazzling | 4.4.2 | Pass |
| Variation in supply parameters | 4.5 | Pass |
| Fire sensitivity | 4.6 | Pass |
| Cold (operational) | 4.7.1.1 | Pass |
| Dry heat (operational) | 4.7.1.2 | Pass |
| Damp heat, steady state (operational) | 4.7.2.1 | Pass |
| Damp heat, steady state (endurance) | 4.7.2.2 | Pass |
| Sulfur dioxide (SO ₂) corrosion (endurance) | 4.7.3 | Pass |
| Shock (operational) | 4.7.4.1 | Pass |
| Impact (operational) | 4.7.4.2 | Pass |
| Vibration, sinusoidal (operational) | 4.7.4.3 | Pass |
| Vibration, sinusoidal (endurance) | 4.7.4.4 | Pass |
| Electromagnetic compatibility (EMC), immunity (operational) | 4.7.5 | Pass |

PASS; NPD = No Performance Determined, NA = Not Apply

Annex according to EN 54-17:2005, EN 54-17:2005/AC:2007

Fire detection and fire alarm system. Part 17: short-circuit isolators

| Essential characteristics | Clauses in this European standard | Mandated level(s) or class(es) |
|---|-----------------------------------|--------------------------------|
| Compliance | 4.1 | Pass |
| Integral status indication | 4.2 | Na |
| Connection of ancillary devices | 4.3 | Na |
| Monitoring of detachable short-circuit isolators | 4.4 | Pass |
| Manufacturer's adjustments | 4.5 | Na |
| On-site adjustments | 4.6 | Na |
| Marking | 4.7 | Pass |
| Data | 4.8 | Pass |
| Additional requirements for software controlled short circuit isolators | 4.9 | Pass |
| Reproducibility | 5.2 | Pass |
| Variation in supply voltage | 5.3 | Pass |
| Dry heat (operational) | 5.4 | Pass |
| Cold (operational) | 5.5 | Pass |
| Damp heat, cyclic (operational) | 5.6 | Pass |
| Damp heat, steady state (endurance) | 5.7 | Pass |
| Sulphur dioxide (SO ₂) corrosion (endurance) | 5.8 | Pass |
| Shock (operational) | 5.9 | Pass |
| Impact (operational) | 5.10 | Pass |
| Vibration, sinusoidal (operational) | 5.11 | Pass |
| Vibration, sinusoidal (endurance) | 5.12 | Pass |
| Electromagnetic Compatibility (EMC), Immunity tests (operational) | 5.13 | Pass |

PASS; NPD = No Performance Determined, NA = Not Apply