

## Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

### APPLICANT

Placed on the market under the name of

## Detnov Security, S.L.

C/ De La Ciència, 30  
08840 Viladecans (Barcelona) Spain

### Produced in the manufacturing plant

C/ De La Ciència, 30  
08840 Viladecans (Barcelona) Spain

### PRODUCT

## Fire detection and fire alarm system

□ Manual call point

**Models:** PCD-200, PCD-200SL

### APPLICABLE REGULATION

## Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

**EN 54-11:2001, EN 54-11:2001/A1:2005**

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

No. 0370-CPR-7364

**Date issued:** 19/09/2025

**First issue date:** 20/12/2024

**Follow-up date:** before 30/09/2026

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the EVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.



**Xavier Ruiz Peña**  
Managing Director  
Conformity Assessment

**Applus<sup>+</sup>**  
certification

**LGAI Technological Center S.A. (APPLUS)**  
**Notified Body No. 0370**

Campus UAB. Ronda de la Font del Carme s/n  
08193 Bellaterra, Barcelona (Spain)



Check the status  
of this certificate

# Certificate

# Technical Annex

Annex according to EN 54-11:2001, EN 54-11:2001/A1:2005

Fire detection and fire alarm system. Part 11: Manual call point

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Marking and data	4.2	Pass
Normal condition	4.3.1	Pass
Alarm condition	4.3.2	Pass
Indicators for alarm condition	4.4	Pass
Reset facility	4.5	Pass
Test facility	4.6	Pass
Shape, dimensions and colours	4.7.2	Pass
Symbols and lettering	4.7.3	Pass
Protection against accidental operation	4.7.4	Pass
Environment category	4.7.5	Pass
Additional requirements for software controlled manual call points	4.8	Pass
Operational performance test	5.2	Pass
Function test	5.3	Pass
Test facility test (operational)	5.4	Pass
Reliability test (endurance)	5.5	Pass
Variation of supply parameters	5.6	Pass
Dry heat (operational)	5.7	Pass
Dry heat (endurance)	5.8	NA
Cold (operational)	5.9	Pass
Damp heat, cyclic (operational)	5.10	Pass
Damp heat, cyclic (endurance)	5.11	NA
Damp heat, steady state (endurance)	5.12	Pass
SO2 corrosion (endurance)	5.13	Pass
Shock (operational)	5.14	Pass
Impact (operational)	5.15	Pass
Vibration, sinusoidal (operational)	5.16	Pass
Vibration, sinusoidal (endurance)	5.17	Pass
Electromagnetic compatibility (EMC) (operational)	5.18	Pass
Enclosure protection	5.19	NA

PASS; NPD = No Performance Determined, NA = Not Apply

Accessories	
<b>TBD-200</b>	Protective plastic cover for indoor manual call points
<b>SMP-200</b>	Manual call point base