

DECLARATION OF PERFORMANCE
DECLARACIÓN DE PRESTACIONES
11-0370-CPR-1190

Product identification

Identificación producto

Model MAD-441, MAD-442
Modelos

Description Addressable Output Modules to Conventional Zones
Descripción Módulos de Salida Analógicos a Zonas Convencionales

Manufacturer Detnov Security S.L.
Fabricante Carrer de la Ciència, 30-32
08840 - Viladecans
Barcelona (Spain)

Use Fire Safety
Uso Seguridad contra incendios

System degree 1
Grado del sistema

Notified Body LGAI Technological Center
Organismo Notificado Ronda de la Font del Carme, s/n
08193 Bellaterra (Barcelona)
Organismo notificado nº 0370

Systems of verification of performance According to regulation nº 305/2011
Sistema de verificación de prestaciones Según reglamento nº 305/2011

Certificate 0370-CPR-1190
Certificado

Completed tasks:

Determination of product-type on the basis of type-testing.
Initial production inspection and production control in the manufacturing facilities.
Surveillance, evaluation and continuous supervision of the production control in the manufacturing facilities.

Tareas realizadas:

Determinación del producto tipo sobre la base de ensayos de tipo.
Inspección inicial de la planta de producción y del control de producción en fábrica
Vigilancia, evaluación y supervisión permanente del control de producción en fábrica.

Signature / Firmado:



Rafael Guisado
Project Manager
Carrer de la Ciència, 30-32
08840 - Viladecans
Barcelona
Spain

.....
Date/ Fecha: 26-09-19

Essential characteristics

Annex according to **EN 54-18:2005, EN 54-18:2005/AC:2007**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Functional test	5.1.4.	PASS
Performance and variation in supply parameters	5.2	PASS
Dry heat (operational)	5.3	PASS
Cold (operational)	5.4	PASS
Damp heat, cyclic (operational)	5.5	PASS
Damp heat, steady state (endurance)	5.6	PASS
Sulphur dioxide (SO ₂) corrosion (endurance)	5.7	PASS
Shock (operational)	5.8	PASS
Impact (operational)	5.9	PASS
Vibration, sinusoidal (operational)	5.10	PASS
Vibration, sinusoidal (endurance)	5.11	PASS
Electromagnetic Compatibility (EMC) Immunity tests	5.12	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

Prestaciones declaradas

Anexo según **EN 54-18:2005, EN 54-18:2005/AC:2007**

CARACTERÍSTICAS ESENCIALES	CAPÍTULO Y APARTADOS EN ESTA NORMA EUROPEA	NIVELES Y/O CLASES MANDATADAS
Ensayo funcional	5.1.4.	PASA
Comportamiento y variación en los parámetros de funcionamiento	5.2	PASA
Calor seco (funcional)	5.3	PASA
Frío (operacional)	5.4	PASA
Calor húmedo cíclico (funcional)	5.5	PASA
Calor húmedo estado estacionario (resistencia)	5.6	PASA
Corrosión por dióxido de azufre	5.7	PASA
Choque (operacional)	5.8	PASA
Impacto (operacional)	5.9	PASA
Vibración sinusoidal (operacional)	5.10	PASA
Vibración sinusoidal (resistencia)	5.11	PASA
EMC	5.12	PASA

PASA; PND = Prestación No Determinada, NA = No Aplica